



INSTALLATION GUIDELINES and GENERAL INFORMATION:

1. See the specific system wiring diagram for the balance of the wiring connections required.
2. All low voltage wiring is #18 AWG, unless otherwise noted.
3. Observe all local and national electrical and building codes.
4. Each system is wired independently and uses an independent 24VAC (model SS106) transformer (or equivalent).
5. Wiring shown is applicable to our model EK117B and/or EK154B Emergency-Call kits only.
6. Wire colors shown are the pigtail wires on the back of the SF117/2A pull cord station(s) and SF154A Push Stations, and CDL123B Dome Lights (with 24VAC buzzer).



42 Central Drive, Farmingdale NY 11735-1202
 (631) 777-5500 Fax: (631) 777-5599
TOLL-FREE Technical Line 1-800-666-4800
 Email: info@alphacommunications.com

TYPICAL WIRING INSTRUCTIONS FOR EK117B Series and EK154B Series

Emergency Call Kits with CDL123B Dome Light and separate SS106 transformer for each light unit.