

Heat-automatic Fire Detectors

COMPANY

Napco Security Technologies Inc
 333 BAYVIEW AVE
 AMITYVILLE, NY 11701 United States

S7386

Model No.	Type	Compatibility Restrictions	Contact Arrangement	Temp Range (°F)	Spacing (Ft)	
					Smooth Ceiling	to Wall or Partition
FW-2-H-E (a)	FT	D6	-	135	50	25
FW-2-H-E-HEAD (a)	FT	D6	-	135	50	25
FW-4-E-HEAD [b]	FT	D6	-	135	50	25
FW-4-EHSC-BASE [a]	FT	D6	-	135	50	25
FW-4-H-E [a]	FT	D6	-	135	50	25
FW-4-H-E-HEAD [a]	FT	D6	-	135	50	25
FWC-FSLC-HEAT-E (b)	FT/ROR	D2	-	135-194	70	35
GEM-HEAT	FT/ROR	D2	NO	135	50	25
GEMC-WL-HEAT	FT/ROR	D5, *1	-	135	50	25
GEMC-WL-HEAT-2	FT/ROR	D5	-	135	50	25
ISEC-HEAT	FT/ROR	D5, *1	-	135	50	25

Base Model	Related Detector	Control Unit Compatibility Restrictions
FW-2-EH6-BASE (a)	-	None
FW-4-EHSC-BASE	DSC-EA,-W, DFE-135, DFE-190, DCD-135, DCD-190	B3
FWC-FSLC-4BE	FWC-FSLC-SH, FWC- FSLC-SH -HEAD, FWC-FSLC-SCH, FWC- FSLC-SCH -HEAD, FWC-FSLC-HEAT-E	B3
FWC-FSLC-6BE	FWC-FSLC-SH, FWC- FSLC-SH -HEAD, FWC-FSLC-SCH, FWC- FSLC-SCH -HEAD, FWC-FSLC-HEAT-E	B3

B3 - For connection to a Listed open area protection smoke or heat detector head with which compatibility was determined by test or a review of circuit parameters. Refer to the manufacturer's installation instructions for a list of compatible models.

D2 - For connection to Listed control units with which compatibility was determined by test or a review of circuit parameters. Interconnection and compatible models indicated on installation wiring diagram for detector (base) and/or control unit.

D5 - For use only with Listed control units with which compatibility was determined by test.

D6 - When using 2-wire bases Listing limited to specific system control unit. Information on compatible control unit indicated on installation drawing of control unit and/or detector. When using 4 wire bases, no restriction on compatibility.

*1 - Intended for Commercial Installations for use with Listed wireless receiver, model GEMC-REVC.

*8 - Intended for Commercial Installations for use with Listed wireless receiver, model GEMC-REVC.

FT - Fixed temperature

FT/ROR - Fixed temperature/rate of rise combination

(a) - Complementary Listing under UROX.S5577

(b) - Detector may be set for FT [Mode 0], FT/15° ROR [Mode 1] or 15° ROR [Mode 2] Operation.

* - must be operated in conjunction with Listed (UOXUOJZ) Model GEMC-RECV series wireless receiver unit, as well as listed (UOJZ) panel model GEMC-255 (also represents GEMC-32, GEMC-96, and GEMC-128) and any compatible panel that have been evaluated.

[a] - Covered under UROX and UQGS

Last Updated on 2024-11-19

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2025 UL LLC."